




Applied Axial Load, kips



**Pile No. IP-13**  
 14-in Square Prestressed  
 Precast Concrete Pile

Pile Length	19.66m
Hammer	D 30-32
Rated Energy	94.77 MN-m
Cushion	254mm Plywood
Final Driving Resistance	64 blows/178mm
Penetration into Bearing Sand	3.66m

FIG\_97: Results of Load Test on 14-in Prestressed Concrete Pile