



Pile No. IP-11 to IP-18	
Section	356mm square
Pile Lengths	18.3 to 20.1m
Hammer	D30-32
Energy	94.77 MN-m
Cushion	254mm Plywood
Measured Energy	30-41 MN-m

Plate Q-06 : Dynamic Capacity Versus Driving Resistance from PDA Tests at Site no. 1