



Pile No. IP-13 <i>14-in Square Prestressed Precast Concrete Pile</i>	
Pile Length	19.66m
Hammer	D 30-32
Rated Energy	94.77 MN-m
Cushion	254mm Plywood
Final Driving Resistance	64 blows/178mm
Penetration into Bearing Sand	3.66m

Plate Q-07: Results Of Axial Compression Load Test: 14 In. Pile At Site No. 1