



Pile No. IP-8 14-in Square Prestressed Precast Concrete Pile	
Pile Length	17.6m
Hammer	D46-32
Energy	145 MN-m
Cushion	229mm Plywood
Final Driving Resistance	7 blows/in
Penetration into Bearing Sands	6.1 m

Plate Q-08: Results of Axial Compression Load Test: Site NO. 2, 356mm Prestressed Concrete Pile